

Parameters	Permissible limits before discharge into sewer without terminal STP or not connected to public sewers	Permissible limits before discharge into public sewers with terminal STP (General standards as per EPA, 1986)
pH	6.5-9.0	5.5-9.0
Suspended Solids	100 mg/l	600 mg/l
Oil & Grease	10 mg/l	20 mg/l
BOD	30 mg/l	350 mg/l
COD	250 mg/l	-
Bio-assay	90% survival of fish after 96 hrs in 100% effluent	90% survival of fish after 96 hrs in 100% effluent
<p><i>Sludge from ETP shall be given to CBWTF for incineration or to TSDF for disposal.</i></p> <p><i>Non-bedded occupiers shall dispose infectious liquid wastes only after treatment by disinfection as per Schedule II (6) of the principal rules</i></p> <p><i>Chemical liquid waste after disinfection/pre-treatment with 1-2% sodium hypo-chlorite solution shall be mixed with other waste water generated in HCF and the combined discharge shall conform to the above standards after final treatment¹⁰³</i></p>		