

Punjab Pollution Control Board

Nabha Road, Patiala

No: 217

Date: 22/3/17

Notification

The Board in its 174th meeting held on 23.12.2016 considered the matter in detail regarding the standards for the discharge of treated domestic effluent at the outlet of sewage treatment plant (STP) for the various towns in the State of Punjab notified vide Board's notification no. SEE(HQ-2)/2016/F.No. Standards/70/370 dated 16.08.2016.

Keeping in view the techno-economic non-feasibility, it has now been decided to amend the said notification and to waive off parameters namely SAR, EC and RSC at the outlet of the sewage treatment plant (STP) of capacity less than 10 MLD. However, the said parameters will remain applicable for STPs of capacity 10 MLD or above.

This will come into force with immediate effect.

Sd/-
Member Secretary

Dated: _____

Endst. No. _____

A copy of the above is forwarded to the following for information and compliance: -

1. The Addl. Chief Secretary, Deptt. of Local Govt. Punjab, Chandigarh.
2. The Principal Secretary, Deptt. of Housing and Urban Development, Secretariat-II, Chandigarh.
3. The Director Local Govt., Punjab, Chandigarh.
4. The Chief Executive Officer, Punjab Water Supply & Sewerage Board, Madhya Marg, Sector 27-B, Chandigarh.

Endst. No. 14118-62

Sd/-
Sr. Environmental Engineer(HQ-2)

Dated: 22/3/17

A copy of the above is forwarded to the following for information and necessary action:-

- 1) The Chief Environmental Engineer, Patiala/Ludhiana/Amritsar/Bathinda, Punjab Pollution Control Board, Patiala.
- 2) The Senior Environmental Engineer, Punjab Pollution Control Board, Zonal Office, PTA-I/II/LDH-I/II/ JAL/ASR/BTI/HQ-1/2/3, Patiala.
- 3) The Senior Scientific Officer, Punjab Pollution Control Board, Head Office, Patiala.
- 4) The Environmental Engineer, Punjab Pollution Control Board, Regional Office, PTA/Mohali/LDHI/II/III/IV/Amritsar/Bathinda/FatehgarhSahib/Sangrur/Jalandhar/Batala/Faridkot & Hoshiarpur.
- 5) The Environmental Engineer(Const.)/HWM/MEGA,(HQ-1/2/3) Punjab Pollution Control Board, Head Office, Patiala.
- 6) The Environmental Engineer(Computer), Punjab Pollution Control Board, Head Office, Patiala with request to upload the Notification on the website of the Board.
- 7) The Scientific Officer (Air Lab), Punjab Pollution Control Board, Head Office, Patiala.
- 8) The Administrative Officer -I/II, Punjab Pollution Control Board, Head Office, Patiala.
- 9) The Senior Law Officers, Punjab Pollution Control Board, Patiala/Ludhiana/Jalandhar.
- 10) P.S. to Chairman/P.A. to Member Secretary, Punjab Pollution Control Board, Patiala.

Sd/-
Sr. Environmental Engineer(HQ-2)

M